



NOTES:

1. No utilities may be located within 2 ft. clear distance of the back of curb.
2. All ditches, tap holes and bore pits must be backfilled and compacted in 6 in. lifts.
3. All street crossings will be bored. A 36 in. min. depth must be maintained from the street surface to the top of the bore hole.
4. Gas mains, power cables and communication lines running parallel with City utilities must maintain a 2 ft. min. clearance from the outside edge to outside edge.



CITY OF LEE'S SUMMIT, MO
PUBLIC WORKS DEPARTMENT
ENGINEERING DIVISION

Gas, Power & Communication Location Detail

Date: 01/08

Drawn By: MJF

Checked By: .

FILE: G-2

Rev:

Rev: